
# **R15C**

# Packaged Terminal Air Conditioner (PTAC)

		Straight cooling n	ominal capacities	
Btuh	9,000	12,000	15,000	18,000
kW	2.6	3.5	4.4	5.3
		R1	5C	

# Specifications and Performance



# **R15C**

Replacement for: American Air Filter series 25 & Others, American Standard 41

**RETROARE**<sup>The</sup> Right Fit for Comfort

ECR International LLC 2201 Dwyer Avenue Utica, NY 13501 e-mail: info@RetroAire.com



P/N 240008359, Rev. A [2/5/2010]

Replacement Packaged Terminal Air-Conditioning / Heat Pump
• Installation, Operation, and Maintenance Manual •

## **Read This First**

### Contents

Read This First	2
To the installer $\ldots$ $\ldots$ $\ldots$ $\ldots$ $\ldots$ $\ldots$	2
General Product Information	3-7
Product description	3
Standard controls and components	3
Factory-installed options (consult the factory)	3
Field-installed options.	3
R15C Chassis	4
R15C Chassis Iso	5
.R15C Cabinet Front	6
PTAC/PTHP Model Coding	7-8
Features	9-10
Optional wall-mounted thermostats	10
Sequence of Operation	11-12
Sequence of Operation	–
	11
Initial Power-Up or power restoration	11 11
Initial Power-Up or power restoration	11 11 12
Initial Power-Up or power restoration	11 11 12 12
Initial Power-Up or power restoration       .	11 11 12 12

### To the installer

Retain this manual and warranty for future reference.

Before leaving the premises, review this manual to be sure the unit has been installed correctly and run the unit for one complete cycle to make sure it functions properly.

To obtain technical service or warranty assistance during or after the installation of this unit, contact your local representative. Visit our web site www.retroaire.com for a local representative listing. For further assistance call 1-800-228-9364.

When calling for assistance, please have the following information ready:

\_\_\_\_\_

Model Number\_\_\_\_

Serial Number

Date of installation

#### NOTICE

The RetroAire<sup>™</sup> replacement PTAC/PTHP is backed by EMI and ECR International and is tested and rated in accordance with:

AHRI Standards 310/380

#### UL-484

Due to ongoing product development, product designs and specifications may change without notice.

Please contact the factory for more information.

### **General Product Information**

### Product description

RetroAire Replacement Packaged Terminal Air Condition/Heat Pumps units are available in straight cooling (PTAC) or as heat pump systems (PTHP). Both the PTAC and PTHP configurations fit the wall sleeves of the units listed on the front cover. Heat pumps (PTHP) reduce energy costs and will operate in mechanical heat mode down to an outdoor temperature of 40°F (4.4°C), Below 40°F (4.4°C) heating is accomplished by an auxillary heat option.

The Retroaire PTAC/PTHP units:

- Use R-410A refrigerant. This refrigerant is not affected by a phase out schedule.
- Include high-efficiency rotary compressors, protected by a 5-year warranty.
- Include an enhanced, high-efficiency heat exchangers.
- Offer two fan speeds.
- Incorporate positive condensate re-evaporation to improve efficiency.
- Have an optional motorized fresh-air feature with a positive pressure seal.

RetroAire PTAC/PTHP ratings meet or exceed ASHRAE 90.1 Standards for energy efficiency:

- PTAC/PTHP units are available in nominal sizes of 9,000 Btuh, (2.6kW) 12,000 Btuh (3.5kW) or 15,000 Btuh (4.4kW).
- PTAC units (straight cooling only) are also available at 18,000 Btuh (5.3kW).
- Energy Efficiency Rating (EER) as high as 10.
- Coefficient of performance (COP) ratings as high as 2.90 for heat pumps.

### Standard controls and components

#### Construction

- 20-gauge galvanized steel construction of chassis.
- Condenser baffle options to accommodate extended wall sleeve applications. (Consult the factory for special order items).
- Powder-coated condenser and evaporator drain pan.
- Foam strip seal for supply air duct.
- Weather strip insulation.

#### Air systems

- Motors are thermally-protected PSC type.
- Air-stream surfaces are insulated with <sup>1</sup>/<sub>4</sub>" fiber-glass or <sup>1</sup>/<sub>8</sub>" (3.2 mm) Volara<sup>™</sup>.
- The indoor fan is a foward-curved type, directly mounted to the motor shaft.
- Unit mount controls include a field selection switch to control indoor fan by either cycling with compressor operation or continuously with the unit.

#### Condensate removal

- The outdoor fan incorporates condensate slinger ring Condensate is thrown onto the coil, where it evaporates, improving system performance.
- Thermostatic drain pan valve for condensate elimination when outdoor temperature drops below 60°F (15°C) (heat pump units only).

#### Controls

- Unit-mounted operating controls include thermostat, fan speed control, heat/cool switch, fan cycle switch, fresh air switch (if equipped)
- Ability to utilize 1-stage or 2-stage thermostat. 2 stage thermostat is capable of activating emergency heat if an auxiliary heat source is available.
- Low ambient protection see "Microprocessor control board" for details.
- Ability to control a normally-open or normally-closed motor valve switch (on hydronic heat units only). Valve controls must be ordered for 24V or line voltage.
- All hydronic heat units include molex plugs for connection of hydronic valve motor.
- Remote mount controls include fan speed control and fresh air switch (if equipped)
- All units are equipped with manual reset high pressure switch which prevents abnormal high pressure operation, increasing compressor reliability.

#### Microprocessor control board

- The universal control board is used in straight cooling, electric resistance heat, hydronic heat, or cooling/heat pump applications.
- Random start timer prevents multiple units from simultaneous startups after power interruption or on initial power-up.
- Fan purge fan remains on for 60 seconds after heat/cool is satisfied.
- Anti-short-cycle compressor protection prevents the compressor from rapid cycling, increases compressor reliability.
- Freeze-protection prevents evaporator coil freeze up, improving compressor reliability.
- Low ambient lockout prevents compressor operation in outdoor temperatures less than 40°F (4.4°C). (On PTHP units supplied with unitmounted control, the control causes automatic changeover to auxiliary heat, if installed.)
- Test operation all timers are temporarily suppressed to allow ease of testing or troubleshooting.
- Control board LED provides self-diagnostic troubleshooting codes, see "Sequence of operation."

#### Factory-installed options (consult the factory)

- 265/277V(12 and 15 only)
- 115V (09 &12 Models Only)
- Corrosion-resistant coil option used for seacoast and harsh-environment usage; coated aluminum fin/copper tube condenser coil.
- Motorized fresh-air damper
- Supplemental electric heat see heat options on "Model coding" on page 7.
- Hydronic heat controls
- Front air intake


### Field-installed accessories

- Hydronic heat the coil assembly is shipped loose for field installation.
- Remote wall thermostat digital 1-stage or 2-stage available.
- Wall sleeves, louvers, and cabinets
- Aquastat delays fan start-up until coil reaches 100°F (38°C) to virtually eliminate "cold" blow condition.
- Hydronic control valve , Water 2 way & 3 way
- Hydronic control valve, Steam 2 way
- Hydronic Isolation valve, 1/2 in Sweat Connection.

Replacement Packaged Terminal Air-Conditioning / Heat Pump • Installation, Operation, and Maintenance Manual •


### General Product Information (continued)

Figure 1 R15C chassis




Replacement Packaged Terminal Air-Conditioning / Heat Pump
• Installation, Operation, and Maintenance Manual •

General Product Information (continued)




Replacement Packaged Terminal Air-Conditioning / Heat Pump
• Installation, Operation, and Maintenance Manual •

Figure 2 R15 Cabinet Front



Replacement Packaged Terminal Air-Conditioning / Heat Pump • Installation, Operation, and Maintenance Manual •


**PTAC/PTHP Model Coding** 



#### Field Installed Accessories [items to be selected during the ordering process]

	Remote thermostat	Sea Coast Coated Coils (Factory Installed, consult factory)
	Hydronic Heat	
	Wall Sleeves. Louvers, & Cabinet (Consult Factory)	

### **PTAC/PTHP Model Coding**



### Features

#### Indoor coil freeze protection (standard)

This feature will prevent the indoor coil from freeze up in the cooling mode.

- Indoor coil freeze up can occur due to a dirty air filter, restricted or poor air flow, low refrigerant charge or low room or outdoor temperatures.
- This in turn can cause compressor damage.
- Should a freeze condition be detected, the compressor and outdoor fan will be switched off for a minimum of three minutes until the freeze condition is satisfied.
- During this time the indoor fan will continue to run to aid in the defrost process.

### Condensate removal (standard)

The RetroAire replacement unit (cooling operation) is designed to eliminate condensate by slinging it onto the outdoor coil.

- Condensate drains through the bulkhead to the area near the outdoor fan.
- As part of its normal operation, the unit will produce condensate and collect it in the base pan of the unit. There it is picked up by the outdoor fan slinger ring and deposited onto the condenser coil. During the cooling season, this improves the unit's efficiency by maintaining reduced refrigeration system pressures.
- Base pan has overflow notches, if too much condensate is produced notches allow condensate to flow out of the basepan and into the wallsleeve out of the building.

Thermostatic drain pan valve (standard on heat pump units) On heat pump models (PTHP), condensate can accumulate in the outdoor drain pan during the heat pump cycle.

- PTHP units include a thermostatic drain valve that opens when outdoor temperatures fall below  $60^{\circ}F(15^{\circ}C)$ .
- When the drain valve opens, condensate flows from the drain pan onto the bottom of the wall sleeve, where it drains to the outside.

• This keeps the base pan free of condensate water, which could otherwise freeze during colder outdoor temperatures.

#### Random start feature (standard)

The random start feature is initiated on initial power-up or after a power interruption.

- The controller adds a random time delay (from 5–120 seconds) on start-up, preventing the compressor from starting.
- This staggers the starting of multiple units in a single facility, preventing a large surge that might occur if all units started at the same time.

#### Anti-short cycle timer (standard)

The microprocessor control uses this timing to prevent short-cycling of the compressor.

- When the compressor cycles off on a heating or cooling call, the controller starts a 180-second timer.
- The compressor will not be allowed to start until this time has elapsed.
- On initial power-up or after a power failure, this timing occurs after the random start timing.

# Power cord with integral safety protection (standard)

All PTAC/PTHP units rated 250v or less are equipped with a power cord with integral safety protection as standard.

- Providing personal shock protection as well as arcing and fire prevention, the device is designed to sense any damage in the line cord and disconnect power before a fire can occur.
- Tested in accordance with Underwriters Laboratories, the cord set also offers a unique "passive" operation, meaning the unit does not require resetting if main power is interrupted.

#### Features

### Heat pump

Heat pump units are "Limited Range" and should be equipped with back-up electric resistance or hydronic heat. Limited Range heat pumps are designed to operate when outdoor temperatures are between 75°F(24°C) and 40°F(4.4°C) and with a maximum indoor temperature of  $80^{\circ}F(26.6^{\circ}C)$ . The unit is equipped with a reversing valve that is energized for cooling and de-energized in heating mode. Electric heating or hydronic heat will operate using the onboard control logic below the operating conditions of the heat pump.

### Hydronic heating (optional)

An optional hydronic heat package may be selected in lieu of electric heat. Heating operation is essentially the same as that of units with electric heat.

#### Aquastat connection (optional)

All replacement PTAC/PTHP's with hydronic heat are supplied with a standard line volt Aquastat connection. The field installed Aquastat delays the fan operation until the hydronic coil reaches a temperature of 100°F (38°C).

### Motorized fresh air damper (optional)

The optional motorized fresh air damper allows fresh air into the space to be conditioned. When the Fresh Air switch is in the "YES" position the damper door is open and allows fresh air into the space. This feature is only available when the indoor fan is on. When the damper door switch is in the "NO" position, the damper door is closed and does not allow air in the space.

#### Optional wall-mounted thermostats

#### Thermostats available from EMI

EMI offers a thermostat that is compatible with your PTAC/PTHP unit.

- Select EMI part number 240008208 from the latest RetroAire price list for this option. This is a single stage, cool/heat, thermostat that can be used in all RetroAire cooling, heating or heat pump applications.
- The thermostat has an adjustable setpoint range of between  $45^{\circ}F(7^{\circ}C)$  and  $90^{\circ}F(32^{\circ}C)$ .
- For heat pumps another option is EMI part number 240008209. This is a 2 stage heat/cool thermostat which allows for emergency heat.

#### Selecting a thermostat (by others)

When selecting a thermostat other than one offered by EMI, choose a single stage heat/cool, 24v thermostat.

Straight cooling with electric heat or hydronic heat (*R10C* — *PTAC's*)

Select a thermostat that is compatible with a cooling/electric heat system.

The thermostat should have "R", "Y", "W", "C" and "G" terminals.

#### Heat pump with electric heat (R\_H-PTHPs)

Select a thermostat that is compatible with a cooling/single-stage heat/heat pump system.

The thermostat should have "R", "Y", "O" and "G" terminals. RetroAireunits are single stage heating only.

The eleactric heat and heat pump will not operate simultaneously.

## **Sequence of Operation**


# The following Sequence of Operation applies to PTAC/PTHP units.

The **R\_\_C** units are straight cool, single stage air conditioners available with electric or hydronic heat.

The **R\_H** units are limited range, single stage heat pump. Mechanical compression heating (heat pump mode) is locked out at outdoor temperatures of approximately 35 °F (1.7 °C) and below. Below these ambient temperatures, the auxiliary electric or hydronic heat will be used.

#### General

The unit is controlled by a microprocessor. Thermostat and control connections are made to the control board.



# Two configuration jumpers are located on the board, see Figure 8. The Heat Pump Configuration Jumper is a 3 pin jumper.

- Straight **Cool** units R\_\_C, the jumper should be located on the outside two pins.
- Heat Pump units R\_\_H, the jumper should be located on the inside two pins.

A second configuration jumper "TEST" allows for the control's internal timers to be by-passed for test purposes. Placing the jumper on the two pins enables the test mode.

A status LED (Light Emitting Diode), LED1 is located on the center of the board. A series of blinks communicates the status of the board. Between the blink sequence is a separation of approximately 2 seconds. The Status Code is listed below.

Trouble Code (Blinks)	Status
1	Normal Operation
2	Anti-Short Cycle Timer Active
3	Outdoor Coil Freeze Protection
4	Indoor Coil Freeze Protection
5	Simultaneous "Y" and "W" Call

### Initial Power-Up or Power Restoration

When power is applied to the unit, either for the first time or after a power failure, the board will initialize itself. During the initialization, LED1 will be lit continuously for approximately 5 seconds. Following the initialization, a random start timer is initiated. This timer adds a randomly selected 5-120 seconds to the start-up sequence, reducing the possibility of multiple units starting at the same time. Once the random start timer has expired, a 180 second Anti-Short Cycle Timer is initiated and the Processor Board Trouble Code LED is set to blink a 2 flash code. This timer prevents the compressor from rapid cycling. After the Anti-Short Cycle Timer expires, the Processor Board Trouble Code LED is set to blink a 1 blink Trouble Code, indicating normal operation.

## R\_\_C / R\_\_H; Cooling Operation

#### ( For unit mount controls)

With the System Switch [SS] set to "Cool", and the Fan Cycle Switch [FCS] set to "On" (Continuous Fan Operation), the indoor fan motor will start. If the Fan Cycle Switch [FCS] is set to "Off" (Cycling Fan Operation), the indoor fan motor will start with a call for cooling from the internal thermostat [T'stat]. If the unit is equipped with a Motorized Fresh Air Damper, and is active with the Fresh Air Switch [FAS], the damper will open with a call for the indoor fan. If the room temperature is below the thermostat setting the fan operation will continue as noted above. If the room temperature is above the thermostat setting, the reversing valve will be energized, the compressor and outdoor fan will start provided the Anti-Short Cycle Timer has timed out from the initial power-up, power restoration or a previous compressor on cycle. Operation will continue until the room temperature satisfies the thermostat. Once the room temperature falls below the set point by  $3 \circ F(2 \circ C)$ , the compressor, outdoor fan motor and reversing valve will de-energize. If the FCS is set to "Off", the indoor fan will continue to operate for 60 seconds after the compressor stops. If the FCS is set to "On", the indoor fan will continue to operate. As soon as the compressor is de-energized, the Anti-Short Cycle Timer will be initialized and will prevent the compressor from starting again for another 180 seconds. While the Anti-Short Cycle Timer is active, the Processor Board Trouble Code LED is set to blink a 2 flash code. After the Anti-Short Cycle Timer expires, the Processor Board Trouble Code LED is set to blink a 1 blink Trouble Code, indicating normal operation.

### Sequence of Operation (continued)

#### NOTE:

- Remote-Mount Cooling Operation depends on the features of the wall-mounted thermostat. By default the fan will cycle with a call for cooling. For thermostats with an **AUTO** / **ON** fan switch, the fan will run continuously if this is "ON" (Continuous Fan Operation). The fan will cycle with a call for cooling if this is set to "AUTO" (Cycling Fan Operation).
- In cooling the units will not start is the indoor air temperature is  $60^{\circ}F(15.5 \text{ }^{\circ}C)$  or below or if the outdoor temperature is below  $40^{\circ}F(4.5^{\circ}C)$ .

### R\_\_C / R\_\_ H; Heating Operation

With the System Switch [SS] set to "Heat", and the Fan Cycle Switch [FCS] set to "On" (Continuous Fan Operation), the indoor fan motor will start. If the Fan Cycle Switch [FCS] is set to "Off" (Cycling Fan Operation), the indoor fan motor will start with a call for heating from the internal thermostat [T'stat]. If the unit is equipped with a Motorized Fresh Air Damper, and is active with the Fresh Air Switch [FAS], the damper will open with a call for the indoor fan. If the room temperature is above the thermostat setting the fan operation will continue as noted above. If the room temperature is below the thermostat setting, the action of the unit will depend on the outdoor temperature and the freeze sensor status.

**NOTE:** Remote-Mount Heating Operation depends on the features of the wall-mounted thermostat. By default the fan will cycle with a call for Heating. For thermostats with an **AUTO** / **ON** fan switch, the fan will run continuously if this is "ON" (Continuous Fan Operation). The fan will cycle with a call for heating if this is set to "AUTO" (Cycling Fan Operation).

- R\_\_H; Mechanical Heating "Heat Pump"
  - "If the outdoor coil temperature remains above 25 °F (-4 °C), the compressor and outdoor fan will start provided the Anti-Short Cycle Timer has timed out from the initial power-up, power restoration or a previous compressor on cycle. Operation will continue until the room temperature satisfies the thermostat. Once the room temperature rises above the set point by 3 °F (2 °C), the compressor and outdoor fan motor will de-energize. If the FCS is set to "Off", the indoor fan will continue to operate for 60 seconds after the compressor stops. If the FCS is set to "On", the indoor fan will continue to operate. As soon as the compressor is de-energized, the Anti-Short Cycle Timer will be initialized and will prevent the compressor from starting again for another 180 seconds. While the Anti-Short Cycle Timer is active, the Processor Board Trouble Code LED is set to blink a 2 flash code. After the Anti-Short Cycle Timer expires, the Processor Board Trouble Code LED is set to flash a 1 blink Trouble Code, indicating normal operation.
- R\_\_H; Auxiliary Heating "Electric" or "Hydronic"

If the outdoor coil temperature falls to 25 °F (-4 °C) or below for 180 seconds at anytime during a heating call, the compressor and outdoor fan motor will be de-energized and auxiliary heat will be energized. The Anti-Short Cycle Timer will be initiated, prohibiting compressor operation for 180 seconds. The Processor Board Trouble Code LED will flash a 3 blink Trouble Code, indicating auxiliary heat operation. Heating operation with auxiliary heat will continue until the outdoor coil sensor reaches 50  $^{\circ}$ F (10  $^{\circ}$ C).

• "Electric Heat"

With the System Switch [SS] set to "Heat", and the Fan Cycle Switch [FCS] set to "On" (Continuous Fan Operation), the indoor fan motor will start. If the Fan Cycle Switch [FCS] is set to "Off" (Cycling Fan Operation), the indoor fan motor will start with a call for heating from the internal thermostat [T'stat]. If the unit is equipped with a Motorized Fresh Air Damper, and is activated with the Fresh Air Switch [FAS], the damper will open with a call for the indoor fan. If the room temperature is above the thermostat setting the fan operation will continue as noted above. If the room temperature is below the thermostat setting, the electric heater is energized until the room temperature increases above the set point by 3 °F (2 °C), the electric heaters will de-energize.

"Hydronic Heat"

If the FCS is set to "On" (Continuous Fan Operation) and the unit has an AquaStat, the indoor fan and fresh air motorized damper operation will be controlled by the Aquastat. If the AquaStat senses a temperature of  $80 \pm 5 \text{ °F} (26 \pm 3 \text{ °C})$ or below, the indoor fan will shut down and the motorized damper will close fresh air door. With a call for heat, a signal from the processor board will activate the water or steam valve. If the unit is equipped with a field installed AquaStat [AS], the indoor fan start will be delayed until the hydronic coil reaches  $100 \pm 5 \text{ °F} (38 \pm 3 \text{ °C})$ . The signal to the water or steam valve will continue until the room temperature rises above the set point by 3 °F (2 °C). If the FCS is set to "Off", the indoor fan will continue to operate for 60 seconds or until the hydronic coil temperature as sensed by the AquaStat reaches  $80 \pm 5 \text{ }^{\circ}\text{F}$  $(26 \pm 3 \text{ °C})$ , whichever occurs first. If the FCS is set to "On", the indoor fan will de-energize if the AquaStat senses a temperature of  $80 \pm 5 \text{ °F} (26 \pm 3 \text{ °C})$  or below.

• "Remote Wall Thermostat Controls"

Cooling and Heating operates identical to unit mount controls. See remote controls manual for control details. Remote units do not use a system switch, or FCS. Replacement Packaged Terminal Air-Conditioning / Heat Pump
• Installation, Operation, and Maintenance Manual •

### **Performance Data**

#### Table 1R15 performance data

Model R15	Cooling	Sensible Heat	EER	Indoor Air Flow	Fresh Air Inlet Flow	Shipping Weight
	Btuh (kW)	Ratio		CFM (L/s)	CFM (L/s)	lbs (Kg)
RC 09	9,500 (2.7)	0.78	10.0	400 (189)	35 (17)	140 (64)
RC 12	12,300 (3.5)	0.70	8.7	400 (189)	35 (17)	140 (64)
RC 15	15,000 (4.4)	0.64	8.2	425 (200)	35 (17)	140 (64)
RC 18	16,300 (4.7)	0.64	8.2	425 (200)	35 (17)	140 (64)

# **Electrical Specifications**

Table 2	R15 - 9.000 BTU	electrical specifications
---------	-----------------	---------------------------

Power Volt —		Comp	ressor		or Fan otor		or Fan otor		Electr	ric Heat			Unit E	lectrica	l Ratings	;
Volt	Min	RLA	LRA	FLA	Нр	FLA	Нр	Htr #	Volt	w	HA	TCA	THA	MCA	MOCP	Plug
115V	104	7.5	47	1.4	0.09	1.6	0.125	N/A	N/A	N/A	N/A	10.5	N/A	12.4	15	5-20P
								0	N/A	N/A	N/A		N/A	6.2	15	6–15P
								3	208	2454	11.8		12.4	15.5	20	C 20D
								3	230	3000	13		13.6	17.1	20	6–20P
208/ 230V	197	3.9	20	0.6	0.08	0.71	0.09	4	208	3271	15.7	5.2	16.3	20.4	25	6-30P
2001								4	230	4000	17.4		18	22.5	25	0-30P
								5	208	4089	19.7		20.3	25.3	30	C 20D
								5	230	5000	21.7		22.3	27.9	30	6-30P
								0	N/A	N/A	N/A		N/A	5.5	15	7-20P
26514	240	2.22	10.0	0.67	0.0	0.71	0.0	3	265	3983	15	47	15.7	19.6	20	7-20P
265V	240	3.32	18.8	0.67	0.8	0.71	0.9	0.9 4	265	5310	20	4.7	20.7	25.9	30	7-30P
								5	N/A	N/A	N/A		N/A	N/A	N/A	N/A

#### Table 3 R15 - 12,000 BTU electrical specifications

	Supply – 1–60	Comp	ressor		or Fan otor		oor Fan otor		Electr	ic Heat			Unit E	lectrica	l Ratings	;
Volt	Min	RLA	LRA	FLA	Нр	FLA	Нр	Htr #	Volt	W	HA	TCA	THA	MCA	MOCP	Plug
115V	104	10.8	53	1.4	0.09	1.6	0.125	0	N/A	N/A	N/A	13.8	N/A	16.5	25	5-20P
								0	N/A	N/A	N/A		N/A	8.3	15	6–15P
								3	208	2454	11.8		12.4	15.5	20	6–20P
								5	230	3000	13		13.6	17.1	20	0-20P
208/ 230V	197	5.6	29	0.6	0.08	0.71	0.09	4	208	3271	15.7	6.9	16.3	20.4	25	6-30P
2500								4	230	4000	17.4		18	22.5	25	0-30P
								_	208	4089	19.7		20.3	25.3	20	< 20D
								5	230	5000	21.7		22.3	27.9	30	6-30P
								0	N/A	N/A	N/A		N/A	7.1	15	7 200
26514	240	1.6	20	0.67	0.00	0.71	00	3	265	3983	15	6.0	15.7	19.6	20	7-20P
265V	240	4.6	20	0.67	0.08	0.71	.09	4	265	5310	20	6.0	20.7	25.9	30	7-30P
								5	N/A	N/A	N/A		N/A	N/A	N/A	N/A

Replacement Packaged Terminal Air-Conditioning / Heat Pump
• Installation, Operation, and Maintenance Manual •

# **Electrical Specifications**

	Supply - 1–60	Comp	ressor	Indoor Fan Motor			or Fan otor		Electr	ric Heat			Unit E	lectrica	l Ratings	;	
Volt	Min	RLA	LRA	FLA	Нр	FLA	Нр	Htr #	Volt	w	HA	TCA	THA	MCA	MOCP	Plug	
								0	N/A	N/A	N/A		N/A	10.9	15	6–15P	
								3	208	2454	11.8		12.4	15.5	20	< 20D	
								3	230	3000	13		13.6	17.1	20	6–20P	
208/ 230V	197	7.4	33	0.6	0.08	1.0	0.25	0.25	4	208	3271	15.7	9.0	16.3	20.4	25	6-30P
2001								4	230	4000	17.4		18	22.5	25	0-30P	
								5	208	4089	19.7		20.3	25.3	30	6-30P	
								5	230	5000	21.7		22.3	27.9	30	0-30P	
								0	N/A	N/A	N/A		N/A	9.5	15	7 200	
2651	240	6	28	0.67	0.08	1.3	0.25	3	265	3983	15	8.0	15.7	19.6	20	7-20P	
265V	240	0	28	0.67	0.08	1.3	0.25	5 4	265	5310	20	8.0	20.7	25.9	30	7-30P	
								5	N/A	N/A	N/A		N/A	N/A	N/A	N/A	

#### Table 4 R15 - Cooling Capacity 15,000 BTU electrical specifications

Table 5	R15 - Cooling Capacity 18,000 BTU electrical specifications
Table 5	<b>The country report of the check and specifications</b>

	Supply – 1–60	Comp	ressor		Indoor Fan Motor		or Fan otor	Electric Heat					Unit E	lectrica	l Ratings	;
Volt	Min	RLA	LRA	FLA	Нр	FLA	Нр	Htr #	Volt	w	HA	TCA	THA	MCA	МОСР	Plug
								0	N/A	N/A	N/A		N/A	12	20	6–15P
								_	208	2454	11.8		12.4	15.5	20	6 200
								3	230	3000	13		13.6	17.1	20	6–20P
208/ 230V	197	8.3	44	0.6	0.08	1.0	0.25	4	208	3271	15.7	9.9	16.3	20.4	25	6 200
2001								4	230	4000	17.4		18	22.5	25	6-30P
								5	208	4089	19.7		20.3	25.3	30	6-30P
								5	230	5000	21.7		22.3	27.9	30	0-30P
								0	N/A	N/A	N/A		N/A	N/A	N/A	N/A
2651	240	NI/A						3	265	3983	15		15.7	19.6	20	7-20P
265V	240	N/A	N/A	N/A	N/A	N/A	N/A 4	265	5310	20	N/A	20.7	25.9	30	7-30P	
								5	N/A	N/A	N/A		N/A	N/A	N/A	N/A

## **Electrical Specifications**

#### IMPORTANT

Due to ongoing product development, designs, specifications, and performance are subject to change without notice. Please consult the factory for further information.

#### NOTICE

Due to EMI's ongoing development programs, design, specifications, and performance data is subject to change without notice. Please consult the factory for further information. For the most current unit/system performance data, please refer to our website, at www.ecrinternational.com, or Environaster International listing of certified products in the ARI certified directory, at www.ahridirectory.org. Tested/Rated in Accordance with ARI 310/380 and UL Standard 484

TAGE	12	5V		250V			265∨	
Ч Ч	15(A)	20(A)	15(A)	20(A)	30(A)	15(A)	20(A)	30(A)
PLUG	<b>G</b> 5-15 P	5-20 P	6-15 P	6-20 P	<b>6-30</b> P	<b>7</b> -15 P	<b>7-20 P</b>	<b>7-30</b> P
RECEPTACLE	0 0 5-15 R	5-20 R		06-20 R	0 G	7-15 R	7-20 R	7-30 R

Replacement Packaged Terminal Air-Conditioning / Heat Pump
• Installation, Operation, and Maintenance Manual •

Notes

	_													_
I       I														

Replacement Packaged Terminal Air-Conditioning / Heat Pump
• Installation, Operation, and Maintenance Manual •

Notes

Replacement Packaged Terminal Air-Conditioning / Heat Pump
• Installation, Operation, and Maintenance Manual •

Notes

_												
_												

ECR International LLC 2201 Dwyer Avenue Utica, NY 13501 e-mail: info@RetroAire.com

