

**UNC/UNH 09-36 DRAIN PAN  
EXTENSION KIT FOR CEILING  
AND FLOOR CONFIGURATION**

**Kit #550001915  
#550001916  
#550001917**

**KIT INSTALLATION INSTRUCTIONS**

**▲ Safety Considerations**

P/N 240007188, Rev. C [04/6/2010]

Installing and servicing air-conditioning equipment can be hazardous. Only trained and qualified service personnel should install, repair, or service air conditioning equipment. *(The use of safety glasses is recommended.)*

**▲ WARNING:** Before removing any access panel, disconnect power to unit. Failure to do so could result in serious injury or electric shock!!


**▲ Tools Required**

- Drill/w ¼" nut driver




**▲ Parts Included**

		Kit Number:	550001915	550001916	550001917
		Used On:	UNH_09-12	UNH_24	UNC_30-36
Description	Qty				
Upper Drain Pan Extension	1	109007338AK	109007336AK	109007330AK	
Lower Drain Pan Extension	1	109007339AK	109007337AK	109007331AK	
Top Left Mounting Bracket	1		109007340	109007332	
Top Right Mounting Bracket	1		109007341	109007333	
Lower Left Mounting Bracket	1		109007342	109007334	
Lower Right Mounting Bracket	1		109007343	109007335	
#10 x 3/8" Screws	8			201000060	
Installation Instructions	1			240007188	



## UNC/UNH 09-36 DRAIN PAN EXTENSION KIT


1. Install brackets connecting the drain pan extensions using the #10 x 3/8" screws supplied as shown in figure #1 (left end) and figure #2 (right end).



2. Refer to Installation and Operating Instructions manual for cabinet removal details.

### FLOOR INSTALLATION


- 3a. Remove designated screws from drain pan in figure #3.



Remove these screws when installing the unit in the FLOOR configuration.

### CEILING INSTALLATION

- 3b. Remove designated screws from drain pan in figure #4.




Remove these screws when installing the unit in the CEILING configuration.

## UNC/UNH 09-36 DRAIN PAN EXTENSION KIT


4. Carefully slip the tab from the lower drain pan extension between the coil and drain pan. Floor configuration shown.



5. Install the mounting brackets to the unused drain pan using 2 - #10 x 3/8" screws supplied. Floor configuration shown.




### FLOOR CONFIGURATION



Drain pan extension installation complete – Floor configuration shown

### CEILING CONFIGURATION



Drain pan extension installation complete – Ceiling configuration shown.

6. Refer to Installation and Operating Instructions manual for further installation details.